

ANSI SLAS 1-2004 (R2012) *(formerly recognized as ANSI/SBS 1-2004)*



for Microplates – Footprint Dimensions

Secretariat
Society for Laboratory Automation and Screening

Contents

	Page
Foreword	3
1 Scope and purpose	4
1.1 Scope	4
1.2 Purpose	4
2 Normative references.....	4
3 Definitions	4
4 Microplate footprint.....	4
4.1 Normal tolerances.....	4
Figure	5
Figure 1- Microplate Footprint	5
Annex	6
Annex A (Informative) Interpretation of Figures	6

Foreword

As early as the first meeting of the Society for Biomolecular Screening (SBS) in 1995, a need for clearly defined dimensional standards of a microplate were identified. At the time, the microplate was already becoming an essential tool used in drug discovery research. At the time, the concept of a microplate was similar among various manufacturers, but the dimensions of microplates produced by different vendors, and even within a single vendors catalog line varied. This often caused numerous problems when microplates were to be used in automated laboratory instrumentation.

In late 1995, members of the SBS began working on defining dimensional standards for the standard 96 well microplate. The first written proposal was released in December 1995 and presented at numerous scientific conferences and journals throughout 1996. This initial proposed standard was officially presented to the membership of SBS for approval at the annual meeting in October 1996 in Basel, Switzerland. Between then and late 1998, various versions of the proposed standards for 96 and 384 well microplates were circulated to the membership of the society. In early 1999, efforts to begin formalizing the proposed standards in preparation for submission to a recognized standards organization were begun. The email ListServ was started in March, and the first regular quarterly meeting of the working committee met in August of that year. To date, the ListServ contains members representing over 100 corporations, educational institutions, and government organizations from over 15 nations.

There is one annex in this standard. Annex A is informative and not considered part of this standard. It is provided as an aid only for the interpretation of specific elements of ASME Y14.5 as they apply to figures in SBS standards.

In July of 2010, SBS merged with The Association for Laboratory Automation (ALA) to form The Society for Laboratory Automation and Screening (SLAS).

Suggestions for improvement of this standard will be welcome. They should be sent to the Microplate Standards Development Committee of the Society for Laboratory Automation and Screening, 100 Illinois Street, Ste 242, St. Charles, Illinois 60174.

This standard was processed and approved for submittal to ANSI by the Microplate Standards Development Committee of the Society for Biomolecular Screening, (now known as the Society of Laboratory Automation and Screening). Committee approval of this standard does not necessarily imply that all committee members voted for its approval. At the time it approved this standard, the committee had the following member organizations:

Marc Feiglin, Co-chair
Carol Homon, Co-chair

Organization Represented

Apogent Discoveries^{1,2}

BD Biosciences¹

Beckman Coulter^{1,2}

Boehringer-Ingelheim³

Co Bio Engineering³

Corning¹

Greiner BioOne¹

Hamilton Co²

Hoffman La Roche³

MatriCal¹

Merck & Co³

Millipore¹

MJ Research^{1,2}

Molecular Devices^{1,2}

REMP²

Tecan²

Thermo Electron²

Whatman¹

Interest groups

1. Manufacturers of microplates (n=10)
2. Manufacturers of instrumentation that utilizes microplates (n=8)
3. Users of microplates that do not fit in either of the previous categories (n=4)

1 Scope and purpose

1.1 Scope

This standard defines the dimensional requirements of the footprint of a microplate as specified in American National Standards covering these microplates.

1.2 Purpose

It is the purpose of this standard to describe the minimal dimensions required of a microplate that is considered to meet the standards. This standard also outlines the conditions required for making necessary measurements. Unless otherwise specified, all dimensions are applicable at 20 degrees C (68 degrees F). Compensation may be made for measurements made at other temperatures.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this American National Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this American National Standard are encouraged to investigate the possibility of applying the most recent editions of the standards listed below. ASME Y14.5M-1994, Dimensioning and Tolerancing

3 Definitions

There are many terms and definitions associated with microplates that have special meaning to the industry. The following are definitions of terms used in this document:

3.1 ASME: Abbreviation for the American Society of Mechanical Engineers

3.2 ANSI: Abbreviation for the American National Standards Institute, Inc.

3.3 SBS: Abbreviation for the Society for Biomolecular Screening.

3.4 SLAS: Abbreviation for the Society for Laboratory Automation and Screening.

4 Microplate footprint

4.1 Normal tolerances

4.1.1 Footprint

4.1.1.1 The outside dimension of the base footprint, measured within 12.7 mm (0.5000 inches) of the outside corners, shall be as follows:

x Length 127.76 mm $\pm$ 0.25 mm (5.0299 inches $\pm$ 0.0098 inches)

x Width 85.48 mm $\pm$ 0.25 mm (3.3654 inches $\pm$ 0.0098 inches)

4.1.1.2 The outside dimension of the base footprint, measured at any point along the side, shall be as follows:

x Length 127.76 mm $\pm$ 0.5 mm (5.0299 inches $\pm$ 0.0197 inches)


x Width 85.48 mm $\pm$ 0.5 mm (3.3654 inches $\pm$ 0.0197 inches)

4.1.1.3 The footprint must be continuous and uninterrupted around the base of the plate.

4.1.2 Corner Radius

4.1.2.1 The four outside corners of the plate's bottom flange shall have a corner radius to the outside of 3.18 mm $\pm$ 1.6 mm (0.1252 inch $\pm$ 0.0630 inches)

Figure



NOTES:

- 1 The drawing standard used is ASME Y14.5M-1994
- 2 The geometry shown is for illustration only and does not imply any preferred or required construction.
- 3 Dimensions shown are: Millimeters / (Inches)
- 4 Dimensions and tolerances do not include draft.
- 5 The footprint must be continuous and uninterrupted around the base of the plate.
- A A tolerance ± 0.5 mm (0.0197 inches) applies overall, a tolerance of ± 0.25 mm (0.0098 inches) applies at zones B-G, C-F, D-J & E-H.


Figure 1- Microplate Footprint

Annex


Annex A (Informative) Interpretation of Figures

Annex A is a general guide to interpreting figures in SLAS (formerly SBS) standards in accordance with ASME Y14.5M-1994. Annex A is not intended to be a substitute for a working knowledge of dimensioning and tolerancing practices contained therein. The specific examples in Annex A are not comprehensive and may or may not apply to the figures in this particular SLAS (formerly SBS) standard.

THIS ON THE DRAWING:




MEANS THIS:




A.1 Specifying datum

THIS ON THE DRAWING:

PER ASME Y14.5M-1994 PARAGRAPH 1.7.3, 4.5.10, 6.3.1.2




MEANS THIS:



A.2 Specifying composite datum


THIS ON THE DRAWING:

PER ASME Y14.5M-1994
PARAGRAPH 1.7.3, 4.5.10, 4.5.7.1




A.3 Application of composite datum

THIS ON THE DRAWING:




MEANS THIS: PER ASME Y14.5M-1994 PARAGRAPH 6.6.3.1

CONTROLLED SURFACE MUST LAY WITHIN A 0.76MM (0.0299 INCH) WIDE TOLERANCE ZONE, PARALLEL WITH DATUM A, AND MUST NOT EXCEED LIMITS OF SIZE




A.4 Parallelism

THIS ON THE DRAWING:



MEANS THIS:



A.5 Tolerances over a limited area